



佛山市美的开利制冷设备有限公司
FOSHAN MIDEA CARRIER AIR-CONDITIONING EQUIPMENT CO., LTD.

DECLARATION OF LONG PIPING APPLICATION

We guarantee the maximum pipe length and elevation of our units as below table.

Sample Name: Duct Split Type Air Conditioner

Life Test Date: June 1st, 2015 ~ Aug 30th, 2015

Test period: 90 days (90*24=2160h)

Testing item: Life test & Performance Test

Test condition: Continuous running, Indoor side: 30 ~ 40°C, Outdoor side: 35 ~ 45°C

Models(Total 3 sets)	Pipe length (M)	Elevation (M)
42QSM024DS 1 unit 38QUS024DS 1 unit	40	20
42QSM036DS 1 unit 38QUS036DS 1 unit	50	25
42QSM048DS 1 unit 38QUS048DS 1 unit	50	25

Conclusion: Life test is passed and the performance data after life test is in normal range. The result is reference for other same level products.

Attached report: No.: 150909420629A003

Note: This declaration becomes invalid if technical or operational modifications are introduced without the manufacturer's consent.

Trademark: **Carrier**

Manufacture's Name: **Foshan Midea Carrier Air-Conditioning Equipment Co. Ltd.**

Manufacture's Address: **Northern of No.5 Industrial District of Midea, ShunDe, FoShan, GuangDong, P.R.C.**

TEL/FAX NO.: **+86-757-26338546/+86-757-26337977**

Name: **SB. Hwang** Signature: 

Position: **Engineering Director**



中国广东省佛山市顺德区北滘镇林港中路 22 号第五工业区
NO.5 INDUSTRIAL DISTRICT, 22 LINGANG ROAD, BEIJIAO, SHUNDE, FOSHAN, GUANGDONG, PRC
电话 Tel: 0086-757-2239-3057 传真 Fax: 0086-757-2633-7977